

## SHRIRAM INSTITUTE FOR INDUSTRIAL RESEARCH

(A unit of Shriram Scientific and Industrial Research Foundation)

19, University Road, Delhi - 110007 (India) An ISO - 9001, 14001 & OHSAS 18001 Certified Institute

Website: www.shriraminstitute.org E-mail id: customercare@shriraminstitute.org

C1/0000101864

1709-1-141-3593

RG1718/1/6249

27/09/2017

25/09/2017

TEST CERTIFICATE

Date 17/10/2017

NO. :

Job No.

**Booking No.** 

**Booking Date** 

Customer Ref No.

**Customer Ref Date** 

Issued To:

Client Code: A0631

ALSTONE INDUSTRIES PVT LTD

ALSTONE HOUSE, 2 E/7, JHANDEWALAN

**EXTENSION** 

**NEW DELHI** 

DELHI-110055

Kind Attn: MS. RAKSHANDA JABEEN

Sample Description:

ONE SAMPLE DESCRIBED AS SAMPLE 1:-ALSTONE WPC DOOR, WAS RECEIVED.

Sampling was not carried out by Shriram Institute for Industrial Research. Samples details provided in the test

certificate are based on declaration by the party.

S.No	Tests	Results	Protocol / Instrument used
1.	Density, Kg/m³	657	ASTM D 1622-03
2.	Filler Content, %	16.5	Thermogravimetric analysis (TGA)
3.	Flexural Modulus, MPa	I182	ISO 178:2010
4.	Vicat Softening Temperature,°C	80	ISO 306:2013
5.	Resistance to Impact by Falling Mass (Using 1 Kg falling mass after conditioning at -10° C for 1 hrs.)	No break	DIN EN 477 : 1995-08
6.	Heat Reversion,%	1.1	DIN EN 479:1995-08
7.	Straightness of Profile (Deviation from straightness)	Nil	EN 12608: 2003

**AUTHORISED SIGNATORY** 

GC-01(Rev-05)

Scanned copies/photocopies or any other copies should be authenticated by reference to the original report.

Page 1 of 2

Phone: 91-11-27667267, 27667983, 27667860 Fig. 1 -27667676, 27667207

EMPLOYEE CODE : ( \(\mu \cdot\)

## **A**

## SHRIRAM INSTITUTE FOR INDUSTRIAL RESEARCH

(A unit of Shriram Scientific and Industrial Research Foundation)

19, University Road, Delhi – 110007 (India) An ISO - 9001, 14001 & OHSAS 18001 Certified Institute

Website: www.shriraminstitute.org
E-mail id: customercare@shriraminstitute.org

**TEST CERTIFICATE** 

NO.: C1/0000101864

ASTM G 154-16

ASTM D 256-10e1

8. Exposure Conditions:

Duration: 100 hrs Lamp: UVA

Wavelength: 340 nm

Irradiance:  $0.89 \pm 0.02$  W/m².nm UV cycle 8 hrs at  $60 \pm 3$  °C Black Panel Temperture Condensation cycle for 4 hrs at  $50 \pm 3$  °C Black Panel

Temperture

(a) Izod Impact Strength, J/m

(i) Befor UV Exposure 11.4 (ii) After UV Exposure 10.1 (iii) Retention, % 11.2

\*\*\*\*

D.O.R: 27-09-2017 D.O.C: 17-10-2017

AUTHORISED SIGNATORY
EMPLOYEE CODE : ( U, \( \( \( \) \) )

GC-01(Rev-05)

Scanned copies/photocopies or any other copies should be authenticated by reference to the original report.

Page 2 of 2

Phone: 91-11-27667267, 27667983, 27667860 Fig. 10-27667676. 27667207